

ORIGINAL



0000142377

Steve Wene, No. 019630
MOYES SELLERS & HENDRICKS
1850 N. Central Ave. Ste. 1100
Phoenix, Arizona 85004
(602) 604-2141
Attorneys for the Company

RECEIVED

2013 FEB 14 P 4:40

AZ CORP COMMISSION
DOCKET CONTROL

BEFORE THE ARIZONA CORPORATION COMMISSION

COMMISSIONERS

BOB STUMP, CHAIRMAN
GARY PIERCE
BRENDA BURNS
SUSAN BITTER SMITH
BOB BURNS

Arizona Corporation Commission

DOCKETED

FEB 14 2013

DOCKETED BY

IN THE MATTER OF THE APPLICATION
OF LIVCO WATER COMPANY FOR
RATE INCREASE

DOCKET NOS. W-02121A-11-0213
W-02121A-11-0257

IN THE MATTER OF THE APPLICATION
OF LIVCO WATER COMPANY FOR
AUTHORITY TO INCUR LONG-TERM
DEBT

**NOTICE OF WATER LOSS
REPORT COMPLIANCE FILING**

Pursuant to Decision No. 72748 ("Decision"), Livco Water Company ("Livco") hereby submits the water loss report. *See Attachment 1.* Based upon communications with Staff and the water loss report compliance provision set forth in the Decision, Livco understands this filing satisfies the compliance requirement regarding water loss monitoring and no further reporting is required. *See Decision at p. 17, lines 6-8.*

////

////

////


1 RESPECTFULLY SUBMITTED this 14th day of February, 2013.

2 MOYES SELLERS & HENDRICKS

3
4 
5 Steve Wene

6 Original and 13 copies of the foregoing
7 filed this 14th day of February, 2013, with:

8 Docket Control
9 Arizona Corporation Commission
10 1200 West Washington
11 Phoenix, Arizona 85007

12 
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

ATTACHMENT 1

Livco Water & Sewer Co.
PO Box 659 Concho, Arizona 85924
ph: (928) 337-2266 fax: (928) 337-3578 e-mail: livco@conchoaz.com
www.conchoaz.com/livco.htm

Explanation of water loss for 2012 (January – December) for Livco Water Co.

Water Pumped vs Sold

Month	Gallons Sold	Gallons Unmetered	Unmetered Comments	Gallons Pumped	% loss
Jan	2,080,000			2,240,800	7%
Feb	1,996,700	30,000	flushing	2,379,500	14%
Mar	1,596,900	20,000	flushing	1,852,700	12%
Apr	2,099,400	20,000	flushing	2,398,500	11%
May	3,336,500	20,000	flushing	3,675,600	8%
June	4,735,300	20,000	flushing	5,142,500	7%
July	4,485,700	200,000	flushing & overflows	5,723,400	16%
Aug	3,061,000	100,000	flushing & overflows	3,589,300	12%
Sept	3,034,900	20,000	flushing	3,325,600	8%
Oct	2,319,300	20,000	flushing	2,659,300	12%
Nov	1,666,100	120,000	flushing & leak	1,983,900	10%
Dec	1,290,400	20,000	flushing	1,501,900	12%
				Ave % loss	10.75%

Explanation of losses:

The controls on both wells failed in July and August causing tank overflows.

Discovered broken customer meters in February and July that had not been recording. Replaced meters.

Underground main line leak detected. Fixed at end of November.

In December, it was discovered that someone is stealing water from the fire hydrant (found a hydrant wrench laying next to a hydrant) We set up a camera near that hydrant but he may be using multiple hydrants. There is no way to estimate the loss on the report. Hydrants cannot be locked because the fire department needs immediate access to them.

There are no known leaks at this time (1/14/13).

Curious about Concho? Visit: www.conchoaz.com